FITNESS CERTIFICATE

To be fiiled by the Inspecting Officer (Asst. Engineer)

(Re: G.O. Ms. 20/70/ PWD Dt. 23 - 01 -1970)

1.	Name of the Officer		: Jomon poulose, Assistant Engineer, LSGD Kuzhur	
2.	Name of the School		: St.Joseph of Tarbes School, Kundoor	
3.	Location with name of Education District/ Sub. District: Kundoor, Irinjalakkuda, Mala			
7.54 7.48	Classification of Building as special Application for fitness certificat GF 4 x 6.02 m - Classroom (4nos) 3 x 5.26 m - Office 4 x 6.02 m - Play Area	e and size FF 7.54 x 6.02 m 7.48 x 5.26 m 5.04 x 5.60 m	: RCC & She - Classroom (3 nos) - Classroom (3 nos) - lab - Staff Room	SF 7.54 x 6.02 m - Classroom (3 nos) 2.35 x 5.64 m -Store Room (1 nos) 7.73 x 5.62 m - computer lab 3.62 x 6.02 m - Sick Room 3.91x 3.02 m - Staff room 5.26 x 7.41 m - Class room

5.Period for which the certificate is issued : 2025-2026

6. Nature of defects, if any
a) Foundation and basement
b) Superstructure
c) Doors and Windows
d) Wood work wrought and put up
e) Roof
f) Flooring
g) Miscellaneous (Cracks, etc.)

7. Any major defects noticed which will render the : No

building unsafe in any manner

3. Whether maintenance works have been done properly: Yes

9. Whether the structure is sound or not for conducting classes: Yes, The structure is safe for conducting classes under normal weather condition only.

Note: 1. The stability of the structure should be examined also with reference to location, altitude, intensity of wind, exposure of flood etc.

2. Any additional observations if deemed necessary for the certificate may be furnished separately with this certificate.

CERTIFICATE

Certified that the school building was inspected by me on conduct classes, for the period under normal weather condition 2025-2026 for the reasons stated above.

Place: Kuzhur

Date: 31 05 2015

(Seal)

(Seal)

(Seal)

(Seal)

(Seal)

(Seal)

(Seal)

(Seal)

Assistant Engineer

Assistant Engineer LID & EW Section Kuzhur Grama Panchayath